

Skill Sheet 13-I-26

Objective 43: Operate a charged attack line from a ladder. (*NFPA® 1001, 5.3.10*)

Student Name: _____ **Date:** _____

Directions

For this skills evaluation checklist, students will operate a charged attack line from a ladder. Students will work as a team to complete this skill. Firefighter positions include: one to remain on ground and advance hose, and two or three to climb. Inform each student of their position.

Equipment & Materials

- Full protective clothing including SCBA
- Charged 1½- or 1¾-inch (38 or 45 mm) hoseline
- Utility strap or rope hose tool
- Properly raised ladder

Criteria & Evaluation Comments

Criteria (determined by the AHJ)

After the candidate has completed the skill sheet, write comments below.

Evaluator/Candidate Comments

Pass

☐

Fail

☐

Evaluator Signature

Date

Student Signature

Date

Skills Evaluation Checklist

Objective 43: Operate a charged attack line from a ladder.

Task Steps		Yes	No
1.	Advance the hoseline up the ladder using the proper procedure for either an uncharged line or a charged line.		
2.	When at desired elevation, lock in using leg lock or Class I harness, leaving both hands free.		
3.	Position the nozzle through the rungs extending it at least 1 foot (0.3 m) beyond rungs.		
4.	Secure the hose to the top or closest ladder rung with a rope hose tool or utility strap.		
5.	Open the nozzle slowly to reduce the effects of nozzle reaction and water hammer.		